



ELEVATION

NOTES:

1. ALL FITTINGS SHALL BE BRASS.
2. FOR 4" AND LARGER METERS, CUSTOMER WILL BE REQUIRED TO PROVIDE DESIGN FOR LBWD APPROVAL AND INSTALL THE REDUCED PRESSURE BACKFLOW DEVICE. LBWD WILL PROVIDE METER.

TEMPORARY CONSTRUCTION METER

WDS - 014



Long Beach Water
 Exceptional Water • Exceptional Service

RECOMMENDED

Robert Johnson

DIRECTOR OF ENGINEERING

APPROVED

Debra Paul

DEPUTY GENERAL MANAGER / CHIEF ENGINEER

DATE: 02-2020

SCALE: N.T.S.

SHEET 1 OF 1