



**NOTE:**

1. FOR INSTALLATIONS BEHIND CURB USE 1" METER BOX IN LIEU OF GATE BOX AND SET TOP OF VALVE 4" BELOW SURFACE.
2. ALL BRASS NIPPLES AND FITTINGS SHALL BE GREASED AND WRAPPED. NO CONTACT WITH CONCRETE SHALL BE ALLOWED.

**BLOW-OFF ASSEMBLY AT DEAD END MAIN**

**WDS - 112**



**Long Beach Water**  
 Exceptional Water • Exceptional Service

RECOMMENDED

*Robert Johnson*

DIRECTOR OF ENGINEERING

APPROVED

*Debra Paul*

DEPUTY GENERAL MANAGER / CHIEF ENGINEER

DATE: 02-2020

SCALE: N.T.S.

SHEET 1 OF 1