



DETAIL

NOTES:

1. ALL BRASS NIPPLES AND FITTINGS SHALL BE GREASED AND WRAPPED. NO CONTACT WITH CONCRETE WILL BE ALLOWED.

REDUCER, DUCTILE IRON PIPE TO 2-INCH COPPER PIPE

WDS - 122



Long Beach Water
Exceptional Water • Exceptional Service

RECOMMENDED

Robert Johnson

DIRECTOR OF ENGINEERING

APPROVED

Shirley Reed

DEPUTY GENERAL MANAGER / CHIEF ENGINEER

DATE: 02-2020

SCALE: N.T.S.

SHEET 1 OF 1