



NOTE:

1. BLOW-OFF FITTINGS ARE TO BE RETURNED TO THE SERVICE YARD WHEN NO LONGER REQUIRED.
2. ALL BRASS NIPPLES AND FITTINGS SHALL BE GREASED AND WRAPPED. NO CONTACT WITH CONCRETE SHALL BE ALLOWED.

TEMPORARY BLOW-OFF ASSEMBLY AT DEAD END MAIN

WDS - 113



APPROVED

Robert J. [Signature]

DIRECTOR OF ENGINEERING / CHIEF ENGINEER

DATE: 02-2020

SCALE: N.T.S.

SHEET 1 OF 1